दुरध्वनी : २५३३१२११ 24339480



ठाणे महानगरपालिका,ठाणे.

महानरगपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी .ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M -697

Date - 26/11/2024

FIRE SAFETY CERTIFICATE

Certified that the New Horizon Scholars School (name of the building or Premises) at Kavesar, Ghodbunder Road, Thane (w) - 400615. (address) Comprised of Lower Ground + Ground + 5th floors owned / occupied by New Horizon Scholars School, Kavesar, Ghodbunder Road, Thane (w) - 400615. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 11/11/2024 (date of inspection) in the presence of Universal Fire & Safety Services Ltd (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes I to X (X/XII) With effect from 25.11.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

1.	Dowan Comer Riger	- Yes	8. MCP/HOOTER	- Yes
2.	Landing Valve (Single Type)	- Yes	9. Generator	- Yes
3.	Hose Reel Drum Assembaly	- Yes	10. Alarm Panal	- Yes
4.	Booster Pump	- Yes	11. ABC Fire Extinguisher 4Kg Cap.	- Yes
5.	Jocky Pump	- Yes	12. ABC Fire Extinguisher 6Kg Cap.	- Yes
6.	Main Pump	- Yes	13. CO2 Fire Extinguisher 3Kg Cap.	- Yes
7.	Standby Pump	- Yes	14. Underground Tank	- Yes

Issued on 25 / 11/2024

(date of issue) at Thane (place) by

Signature with seal:

Name

: Mr. Girish. M. Zalke

Designation

: Chief Fire Officer, Thane

Name & Address of Department/ Office: Chief Fire Officer, Thane

Municipal Fire Brigade, Thane.

To

New Horizon Scholars School Kavesar, Ghodbunder Road, Thane (w) - 400615. (Name & Address of the Institution)

ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)