



नवा मुंबई
महानगरपालिका

Municipal Corporation

पर्यावरण प्रयोगशाला
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882

JAS-ANZ



M4930112IL

ISO 9001:2015 Certified

NMMC/Environment Laboratory/23/2025-2026

Date : 15/05/2025

Date of sample received. : 15/05/2025 Date of sample testing : 15/05/2025 to 19/05/2025

Customer's Name and Location : New Horizon Scholar's School,
Sec-13, Plot No. 5, Airoli,
Navi Mumbai 400 708

TEST REPORT


Sr. No.	Testing Parameter	Test Result	Test Standards (IS 10500 : 2012)
01	pH	7.3	6.5 - 8.5
02	Turbidity	0.0	Max. 5.0 N.T.U.
03	Residual Chlorine	Nil	Min. 0.2 mg/l
04	Bacteriological Test		
	Total Coliforms	0	0 per 100 ml
	E. Coli	- ve	- ve
	F. Coli	- ve	- ve

Test Report No. : 23

Date : 19/05/2025

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.

Lab Chemist



Lab Incharge

Environment Laboratory
Navi Mumbai Municipal Corporation