

ठाणे महानगरपालिका

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष POLLUTION CONTROL CELL



Tel: +91-22-25362916

E-mail: pcctmc@gmail.com

चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No.: 25375711

Ref./T.M.C./P.C.C./V.Lab - 217 Sample No.: **R55**

Date: 25 April 2025

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation: M/S New Horizon Scholars School

Address: Hiranandani Estate, Kolshet, Thane (W)- 400607

E_mail ID: nhssvl.store@newhorizonsms.com; nhssr.stores@newhorizonsms.org

Date of receiving Sample: 24 April 2025

Sample Collected by : TMC Representative (Sachin Kharade)

Type of Water Sample: Storage Drinking

Parameters	Results	Limits as per IS 10500
рН	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	3.0	5 NTU
Chloride	48.0	250 mg/L
Total Hardness	70.0	300 mg/L
Total Coilform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark: The Sample is Microbiologically & Chemically Potable.

Prabhakar Sonawale

Thane Municipal Corporation, Thane

of Paral Kerr

Omsatvashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking Water sample received to our Vakratunda Laboratory on 24/4/2025. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/LOS/PLC/000061/24-25 dated 09.7.2024

This Report has been Signature Digitally.

Ma Principal **New Horizon Scholars School** Hiranandani Estate, Thane.

New Horizon Scholars School Hiranandani Estate, Thane