



**नवी मुंबई
महानगरपालिका**

पर्यावरण प्रयोगशाळा
२ रा मजला, बहुउद्देशीय इमारत, सेक्टर क्र.२०,
बेलापूर गाव, बेलापूर तलावाच्या जवळ,
सी.बी.डी. बेलापूर, नवी मुंबई-४०० ६१४
दूरध्वनी:
ई-मेल:

**Navi Mumbai
Municipal**

Environment Laboratory
2nd Floor, Bahuuddeshiya Building, Sector
No.20, Belapur Village, Near by Belapur
Lake, C.B.D. Belapur, Navi Mumbai-400 614
Telephone:
E-mail:



Ref. No./NMMC/Env. Lab - Q111

Date: 03 November 2025

Sample ID: 8876

Water Analysis Report

Name Of the Customer: New Horizon Scholars School (3rd Floor Boys Wash Room)

Address: Sector 13, Airoli

E-mail: nhssa.store@newhorizonsms.com

Mobile No.: 9702177932

Date of receiving Sample: 31 October 2025

Sample Collected by: Party

Type of Water Sample: Drinking Water (Drinking Water Sample Testing)

Sample Testing Date: 31 October 2025 to 03 November 2025

Testing Parameters	Test Results	Test Standards (IS 10500:2012)
pH	7.2	6.5-8.5
Turbidity	0.0	Max. 5 NTU
Residual Chlorine	Nil	Min. 0.2 mg/L
MPN	0	0/100 ml
E-Coli	- Ve	- Ve
F-Coli	- Ve	- Ve

Conclusion: Test results of the sample are based on the sample submitted in the laboratory.

Remark: The Sample Is Within Limit.

This is the analysis report of the Drinking Water (Drinking Water Sample Testing) sample received to our Environment Laboratory on 31 October 2025. This further acknowledges that you have paid the charges Rs. 672/- vide Receipt No. ACC/2526/000623 dated 31 October 2025.

Analysed By

Pravin Ghadi

Lab Chemist, Environment Laboratory
Navi Mumbai Municipal Corporation

Checked By

Jitendra Rawal

Lab Incharge, Environment Laboratory
Navi Mumbai Municipal Corporation

- End of Report -