



ठाणे महानगरपालिका  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE  
प्रदूषण नियंत्रण कक्ष  
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,  
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6<sup>th</sup> November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 3337  
Sample No. : R1085

Date : 11 March 2026

**Water Analysis Report**

TMC/PCC/20/RO

Name Of the Organisation : M/S New Horizon Scholars School

Address : Vasant Lawns, DP Road, Opp. TCS, Subhash Nagar, Thane West, Thane,  
Maharashtra 400606

E\_mail ID : nhssvl.store@newhorizonsms.com

Date of receiving Sample : 10 March 2026

Sample Collected by : Bhushan Tawade

Type of Water Sample : Storage Drinking (1st Sample)

Parameters	Results	Limits as per IS 10500
pH	7.10	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	1.0	5 NTU
Chloride	20.0	250 mg/L
Total Hardness	50.0	300 mg/L
Total Coliform Bacteria ( MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

11-Mar-26

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

11-Mar-26

Nirmitee N. Salgaonkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (1st Sample) Water sample received to our Vakratunda Laboratory on 10/3/2026. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 7020/- vide Receipt No.TMC/LOS/PLC/0000118/25-26 dated 18.07.2025

This Report Is Digitally Signed And Approved.

**Principal**  
New Horizon Scholars School  
Vasant Lawns, Thane

