



ठाणे महानगरपालिका, ठाणे  
THE MUNICIPAL CORPORATION OF THE CITY OF THANE  
प्रदूषण नियंत्रण विभाग  
POLLUTION CONTROL DEPARTMENT



मुख्यालय : महापालिका भवन, सरसेनानी अरुणकुमार वैद्य मार्ग, चंदनवाडी, पांचपाखाडी, ठाणे - ४०० ६०२.

pcctmc.ho@gmail.com

Pollution Control Lab, Vartak Nagar Ward Office, Vartak Nagar, Thane (W). Tel. No. : 25881751

Ref./TMC/PCC/VTN/31012/2025-26

Date : 03/11/2025

Sample No. : 1672

STP Lab Code : MM02017

**Water Sample Analysis Report**

Name Of the Organisation : New Horizon Scholars School  
Address : Hiranandani Estate, Thane

E-Mail : nhsst.store@newhorizonsms.com;  
nhssr.principal@newhorizonsms.com;  
nhssr.stores@newhorizonsms.org;  
tmcpsc.vaklab@gmail.com

Mobile No. : 7208021242; 9819221972

Date of receiving Sample : 27 October, 2025

Sample Collected by : By Party (New Horizon Scholars)

Type of Water Sample : Sewage Treatment Plant

Parameters	Results	Limit
pH	7.77	6.5 - 8.5
COD	24.00	50 mg/L
Suspended Solids	BDL (<10)	100 mg/L
BOD	8.00	10 mg/L
Oil & Grease	3.00	10 mg/L
Residual Chlorine	>1	mg/L
MPN	0.00	230/100 ml
E-Coli	Absent	0/100 ml
F-Coli	Absent	0/100 ml

\* All results are in ppm except pH.

Remark : The analyzed parameters are within limit.

This is the analysis report of the sample received to our Laboratory on 27/10/2025. This further acknowledges that you have paid the charges Rs. 25920/- vide Receipt No. TMC/LOS/PLC/000275/24-25 (Jan 25 - Dec 25) dated 28/02/2025.

Analysed by

Bhushan Tawade

Trainee Chemist, PCC

Thane Municipal Corporation

Checked by

Vishal V. Hinge

LA, PCC

Thane Municipal Corporation

Approved by

Akash Jagtap

Jr. Chemist, PCC

Thane Municipal Corporation

Ma

Principal

New Horizon Scholars School  
Hiranandani Estate, Thane.

Manager

New Horizon Scholars School  
Hiranandani Estate, Thane