

	नवी मुंबई महानगरपालिका पर्यावरण प्रयोगशाला २ रा मजला, बहुउद्देशीय इमारत, सेक्टर क्र २०, बेलापूर गाव, बेलापूर तलावाच्या जवळ, मो. वी. डी. बेलापूर, नवी मुंबई - ४०० ६१४ दूरध्वनी: ई-मेल	Navi Mumbai Municipal Environment Laboratory 2nd Floor, Bahuuddeshiya Building, Sector No.20, Belapur Village, Near by Belapur Lake, C.B.D. Belapur, Navi Mumbai-400 614 Telephone E-mail	
	Ref. No./NMMC/Env. Lab - Q193 Sample ID: 14207		

Date: 13 April 2026

Water Analysis Report

Name Of the Customer: New Horizon Scholars School(3rd Floor)
Address: Sector 13, Airoli
E-mail: nmmcwqms@tbd.com
Mobile No.: 9702177932
Date of receiving Sample: 13 April 2026
Sample Collected by: Party
Type of Water Sample: Drinking Water (Drinking Water Sample Testing)
Sample Testing Date: 13 April 2026 to 13 April 2026

Testing Parameters	Test Results	Test Standards (IS 10500:2012)
pH	6.9	6.5-8.5
Turbidity	1.1	Max. 5 NTU
Residual Chlorine	Nil	Min. 0.2 mg/L
MPN	0	0/100 ml
E-Coli	- Ve	-ve
F-Coli	- Ve	-ve

Conclusion: Test results of the sample are based on the sample submitted in the laboratory.

Remark: The Sample Is Within Limit.

This is the analysis report of the Drinking Water (Drinking Water Sample Testing) sample received to our Environment Laboratory on 13 April 2026. This further acknowledges that you have paid the charges Rs. 672/- vide Receipt No. ACC/2526/001090 dated 07 April 2026.

Analysed By
Pravin Ghadi
 Lab Chemist, Environment Laboratory
 Navi Mumbai Municipal Corporation

Checked By
Vivek Joshi
 Lab Incharge, Environment Laboratory
 Navi Mumbai Municipal Corporation

- End of Report -

This is a computer generated report and no signature is required.


PRINCIPAL
NEW HORIZON SCHOLARS SCHOOL
 Airoli, Navi Mumbai - 400 708


MANAGER
NEW HORIZON SCHOLARS SCHOOL

Page 1 of 1