



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
 चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362915

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 982
 Sample No. : 5295

Date : 9 July 2026

Water Analysis Report

TMC/PCC/20/R0

Name Of the Organisation : M/S New Horizon Scholars School, Rodas

Address : Hiranandani Estate, Thane (W)- 400607

E_mail ID : nhscholarsthane@gmail.com; nhssr.store@newhorizonsms.com

Date of receiving Sample : 08 July 2026

Sample Collected by : Prabhakar Sonawale


Type of Water Sample : Storage Drinking(2nd SAMPLE)

Parameters	Results	Limits as per IS 10500
pH	7.12	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	1.0	5 NTU
Chloride	30.0	250 mg/L
Total Hardness	45.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By




9-Jul-26

Sanchita S. Kadlak

Thane Municipal Corporation, Thane

Authorised by



9-Jul-26

Nirmitee N. Salgaonkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking(2nd SAMPLE) Water sample received to our Vakratunda Laboratory on 8/7/2026. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 7020/- vide Receipt No.TMC/LOS/PLC/000005/26-27 dated 06.04.2026

This Report Is Digitally Signed And Approved.



Principal
New Horizon Scholars School
Hiranandani Estate, Thane.



Manager
New Horizon Scholars School
Hiranandani Estate, Thane