



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 2364
Sample No. : Q996

Date : 26 November 2024

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S New Horizon Scholars School

Address : Vasant Lawns, DP Road, Opp. TCS, Subhash Nagar, Thane West, Thane,
Maharashtra 400606

E_mail ID : nhssvl.store@newhorizonsms.com

Date of receiving Sample : 25 November 2024

Sample Collected by : TMC Representative (Bhushan)

Type of Water Sample : Storage Drinking

Parameters	Results	Limits as per IS 10500
pH	7.40	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	22.0	250 mg/L
Total Hardness	42.0	300 mg/L
Total Coilform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

26-Nov-24

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

26-Nov-24

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking Water sample received to our Vakratunda Laboratory on 25/11/2024. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/LOS/PLC/000061/24-25 dated 09.7.2024

This Report has been Signature Digitally.